



Jon S. Corzine
Governor

State of New Jersey
Department of Community Affairs
Division of Codes and Standards
PO Box 802
Trenton, New Jersey 08625-0802



Susan Bass Levin
Commissioner

FTO-4

Date: **November 2, 1992**
Code Ref. Update: **June 2006**

Subject: **Exemption from Floor
Drain Requirement for
Gas Stations**

Reference: **N.J.A.C. 5:23-3.15,
Plumbing Subcode,
Section 6.3**

A recently enacted Federal Environmental Protection Agency standard (the "TC Rule") makes gasoline station effluent, which contains benzene, unsuitable for discharge into storm or septic sewer systems. Additionally, in some municipalities, the local sewer authority will not accept the discharge of benzene containing effluent into the sanitary sewer, either.

In response to this rule, a major oil company has asked that gas stations be exempt from the State plumbing code's requirement for floor drains. Other automotive facilities with bays and drains, such as repair facilities and dealerships, may have the same problem. Applicants who have no legal method of discharge should be allowed to request a variation from the requirement to install floor drains and should be permitted to remove or cap those which exist.

While some applicants (with thoughts of other building uses in the future) may agree to install and cap required drains, other gas station applicants should be exempt upon request. Federal fines of up to a million dollars a day for discharge of benzene make elimination of the drains a reasonable way to ensure that there will be no accidental dumping or discharge into sewer or septic systems, as these are not legal repositories for effluent.

In the absence of floor drains, waste will be containerized.

Charles M. Decker, AIA
Assistant Director
Construction Code Element
Division of Codes and Standards

**PURSUANT TO THE AUTHORITY OF N.J.S.A. 52:27D ET SEQ., AS AMENDED, THIS
FORMAL TECHNICAL OPINION IS CONSIDERED TO BE BINDING UPON ALL CODE
OFFICIALS.**

FORMAL TECHNICAL OPINION